

RESOLUTION: REPLACEMENT OF HEATING SYSTEM BOILER AT THE L.K.P. COMMUNITY CENTER

WHEREAS, the interior components of the heating system boiler at the L.K.P. Community Center have deteriorated to the point of making the boiler non-operational, thus requiring replacement of the boiler, and

WHEREAS, the Town solicited bids for replacement of the boiler and received the following three quotes:

Creekside Service Inc.	\$
74 North Chapel Street	
Gowanda, NY 14070	

Keiffer Southtown Enterprises, Inc.	\$
S4945 Southwestern Blvd	
Hamburg, NY 14075	

NOW THEREFORE BE IT RESOLVED, that the Collins Town Board hereby accepts the proposal of _____ to replace the heating system boiler at the L.K.P. Community Center at a cost of \$_____ and that the funds be taken from the Town's 2019 Budget line A1620.470 Shared Services-Improvements, and

BE IT FURTHER RESOLVED, that the Collins Town Board authorizes payment of any required deposit at the time of proposal acceptance.

RESOLUTION: CLEANING OF THE INTERIOR BOTTOMS OF THE WATER DISTRICT #1 AND WATER DISTRICT #3 WATER STORAGE TANKS

WHEREAS, the WD#1 and WD#3 water storage tanks were inspected on July 25, 2018 by Atlantic Underwater Services Inc., and

WHEREAS, their inspection reports identified that 1 to 5 inches of bottom sediment exist in the WD#1 storage tank and 1 inch or less of bottom sediment exist in the WD#3 storage tank, and

WHEREAS, the Erie County Health Department has conveyed that the removal of sediment from the tanks is a top water quality concern,

WHEREAS, the Town solicited bids for removal of the sediment existing on the bottom of WD#1 and WD#3 storage tank and received the following proposals:

Atlantic Underwater Services Inc	\$3,200.00 for each tank totaling \$6,400.00
2538 State Route 8	
Lake Pleasant, NY 12108	

SUEZ Utility Service Co., Inc
435 Murwood Lane
Webster, NY 14580

Declined to submit proposal

Statewide Aquastore, Inc
6010 Drott Drive
East Syracuse, NY 13057

Declined to submit proposal

THEREFORE BE IT RESOLVED, that the Collins Town Board hereby accepts the proposal of Atlantic Underwater Services, Inc. to clean the interior tank bottoms of WD#1 and WD#3 water storage tanks at a cost of \$3,200.00 for each tank and that the funds be taken from _____.