

# ***Annual Drinking Water Quality Report for 2020***

## ***Village of Gowanda***

*27 East Main St.*

*Gowanda, N.Y. 14070*

*Public Water Supply ID# NY0400340*

## ***Prospect Street Water District***

*P.O Box 250*

*Perrysburg, NY 14129*

*Public Water Supply ID# NY0430098*

### **INTRODUCTION**

To comply with State regulations the Village of Gowanda will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Kirk Trumpore, Chief Water Operator in Responsible Charge, at 716-532-3353. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Village board meetings.

### **WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our system serves the Village of Gowanda and Prospect Street Water District. We have two water sources. One source is the Allen Springs, and the second is a groundwater source (well #1). Water is filtered to remove contaminants. During this time, chlorine is added to disinfect the water and fluoride is added to improve the dental health of the community. The treated water is stored in a 1.7 million gallon reservoir for distribution. In May 2016 we received approval from the Cattaraugus County Health Department to blend the water from the springs and well to bring the barium concentration from the well into compliance. During 2020, our system did not experience any water use restrictions.

In 2003, the NYS DOH completed a source water assessment for our water system, based on available information. Possible and actual threats to the drinking waters sources were evaluated. The source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential contamination of the source water. It does not mean that the water delivered to consumers is or will become contaminated. See section "ARE CONTAMINANTS IN OUR DRINKING WATER?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, one of our water sources is the Allen Springs. The amount of agricultural lands in the assessment area results in elevated potential for protozoa and pesticide contamination. However, please note that our water is continuously disinfected to ensure that the finished water delivered into your home meets the NYS drinking water standards for microbial contamination.

A copy of this assessment, including a map of the assessment area, can be obtained by contacting us as noted above.

## FACTS AND FIGURES

Our water system serves 2,800 consumers through 1,447 service connections in the Village and 95 consumers through 47 connections in the Perrysburg TWD# 2. The amount of water produced in 2020 was 116,727,000 gallons for an average of 319,800 gallons per day. The amount delivered to customers was 63,681,216 gallons. This leaves an unaccounted total of 53,045,784 gallons, or roughly 46%. The water loss was due to backwashing sand filters, leakage, bulk water sales, firefighting and main flushing. In 2020, village water customers were charged \$40.00 minimum for the first 4,000 gallons and \$5.25 for each additional 1,000 gallons of water. The annual average village water charge, per user, was \$150. Village of Gowanda also sells bulk water to the Town of Perrysburg to serve the Prospect Street water district.

## ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: coliform bacteria, turbidity, inorganic compounds, nitrate, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Cattaraugus County Health Department at (716) 701-3386. More information is available from the EPA website: <https://www.epa.gov/dwreginfo/drinking-water-regulations>.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Range)	Unit Measure -ment	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
<b>Disinfectant</b>							
Chlorine Residual -Gowanda Village	No	2020	Avg. = .60 (.2 - 1.3)	mg/l	N/A	MRDL = 4	Water additive used to control microbes.
-Prospect WD	No	2020	Avg. = .61 (.24 - 1.38)				
<b>Microbiological Contaminants</b>							
Total Organic Carbon - Filtered	No	2020	Avg. = .92 (.63 - 1.23)	mg/l	N/A	TT	Naturally present in the environment.
Total Organic Carbon - Raw	No	2020	Avg. = 1.11 (.63 - 1.41)	mg/l	N/A	TT	Naturally present in the environment.
Turbidity <sup>1</sup>	No	8/4/20	High = .26	NTU	N/A	TT = 0.3	Soil runoff.
Turbidity <sup>1</sup>	No	2020	100% ≤ 0.3	NTU	N/A	TT = 95% of samples ≤ 0.3 NTU	Soil runoff.
Distribution Turbidity <sup>2</sup>	No	3/2020	0.12	NTU	N/A	TT = ≤ 5.0	Soil runoff.
<b>Inorganic Contaminants</b>							
Barium - Spring	No	2018	Avg. = .111 (.104 - .116)	mg/l	2.0	MCL = 2.0	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
- Well #1	No	8/12/20	1.6				
Copper <sup>3</sup>	No	6/20/18 to 6/27/18	109 (10 - 120)	ug/l	1,300	AL = 1,300	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Fluoride	No	2020 Daily	.64 - .82	mg/l	N/A	MCL = 2.2	Water additive that promotes strong teeth.

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Range)	Unit Measure -ment	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Lead <sup>4</sup>	No	6/20/18 to 6/27/18	2.4 (<1 – 3.1)	ug/l	0	AL = 15	Corrosion of household plumbing; erosion of natural deposits.
Nitrate	No	8/12/20	High = 2.93 (<1 – 2.64)	mg/l	10	MCL = 10	Run off from fertilizer; leaching from septic tanks, sewage; erosion from natural deposits.
Sodium – Well #1	No	8/12/20	44	mg/l	N/A	See Health Effects <sup>5</sup>	Naturally occurring; road salt; water softeners; animal waste.
<b>Disinfection Byproducts</b>							
Haloacetic Acids - Village	No	2020	LRAA Avg. = 32 (ND - 34 )	ug/l	N/A	MCL = 60	By-product of drinking water disinfection needed to kill harmful organisms.
- District	No	8/11/20	9.4				
Total Trihalomethanes - Village	No	2020	LRAA Avg. = 40 (22 - 79)	ug/l	N/A	MCL = 80	By-product of drinking water chlorination needed to kill harmful organisms.
- District	No	8/11/20	43.1				

**Notes:**

1 - Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. Our highest turbidity measurement for 2020 was 0.26 NTU which occurred on 8/4/2020. State regulations require that turbidity must always be below 1.0 NTU. Also, the regulations require that 95% of the turbidity samples collected have measurements below 0.3 NTU. As you see in the above table, we met the turbidity performance standard requirements throughout 2020.

2 - Our highest average monthly distribution turbidity measurement of 0.12 NTU occurred in March 2020. This value is below the turbidity standard of 5 NTU assigned to our system.

3 - The level presented represents the 90<sup>th</sup> percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, ten samples were collected at your water system and the 90<sup>th</sup> percentile value was the second highest value, 109 ug/l. The action level for copper was not exceeded at any of the sites tested.

4 - The 90<sup>th</sup> percentile level for lead was 2.4 ug/l. None of the sites exceeded the action level of 15 ug/l.

5 - Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets.

**Definitions:**

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Locational Running Annual Average (LRAA):** This is a calculation of the average of all the readings in the year preceding the date of sampling for a particular sample site.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Micrograms per liter (ug/l):** Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

**Milligrams per liter (mg/l):** Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Nephelometric Turbidity Unit (NTU):** A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected at values well below the level allowed by the State. Regardless, we are required to provide the following information on lead in drinking water:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a

result of materials used in your home's plumbing. The Village of Gowanda is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

## **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

On March 15, 2018, the CCHD conducted a sanitary survey of the Village water system. One deficiency listed was that in the event of a chlorine gas leak, gas cylinders would continue to leak until emergency crews arrive, potentially exposing surrounding neighbors to a life threatening hazard. To correct this violation we need to install automatically closing emergency gas cylinder valves. This will protect employees, emergency responders and nearby residents. We are working with the CCHD to ensure that the required corrective action is being taken in the very near future.

## **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

## **INFORMATION ON FLUORIDE ADDITION**

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a properly controlled level. We monitor fluoride levels on a daily basis to ensure that the fluoride supplement in your water provides optimal dental protection. None of the routine monitoring results showed fluoride levels that approach the 2.2 mg/l MCL for fluoride.

## **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ♦ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ♦ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ♦ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ♦ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ♦ Turn off the tap when brushing your teeth.
- ♦ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ♦ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ♦ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances. Then check the meter after 15 minutes. If it moved, you have a leak.

## **CLOSING**

Thank you for allowing us to continue to provide your family with quality drinking water this past year. We ask that all our customers help us protect our water sources, which are the heart of our community and our way of life. Please call our office if you have questions.